


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040684	Main Street: W_MOREHEAD_ST	Cross Street: N/A	Location: N
ADA ID: E604A9F89EBD	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

810.2.4, R308.1.1.2

CATS Stop ID: 33440

CATS Stop Description: Morehead St & Grandin Rd

CATS Route ID: 5

CATS Route Name: Sprinter

Total Cost: \$ 2750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	158.0
No	Boarding Area Slope %	3.4
Yes	Boarding Area XSlope %	1.9
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	62.0
Yes	PAR 1 Slope %	1.4
Yes	PAR 1 XSlope %	0.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	62.0
Yes	PAR 2 Slope %	1.8
Yes	PAR 2 XSlope %	0.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.6
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	60.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	0.0
Yes	Clear Floor Space XSlope %	1.2
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

