


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10030535	Main Street: LITTLE ROCK RD	Cross Street: N/A	Location: W
ADA ID: E7014A087EF3	Overall Compliance: No	Severity Score: 40	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

**CATS ID ON SIGN SHOWED NEW ID
BUT WAS NOT LEGIBLE, CATS ID
ON ARCGIS MAP 14340**

PROW/ADA:

**305.2, 402.2, 810.2.4, 810.3, R302,
R308.1.1.2, R404.1, R404.2**

CATS Stop ID: **14340**
CATS Stop Description: **Little Rock Rd & I-85**
CATS Route ID: **8**
CATS Route Name: **Tuckaseegee Road**

Total Cost: \$ **3750.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	179.0
Yes	Boarding Area Length (in)	125.5
No	Boarding Area Slope %	3.5
No	Boarding Area XSlope %	4.6
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	3.9
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	87.0
Yes	Clear Floor Space Length (in)	59.0
No	Clear Floor Space Slope %	3.0
No	Clear Floor Space XSlope %	4.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

