


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 1002285	Main Street: VAN_LANDINGHAM_RD	Cross Street: N/A	Location: E
ADA ID: E9EF73ACC2B5	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.6,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.7
No	Boarding Area XSlope %	2.6
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
No	PAR 1 Slope %	2.6
Yes	PAR 1 XSlope %	1.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.8
Yes	PAR 2 XSlope %	0.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	60.0
N/A	Clear Floor Space Length (in)	60.0
N/A	Clear Floor Space Slope %	0.1
N/A	Clear Floor Space XSlope %	1.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.5
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 33010

CATS Stop Description: UNCC- Mary Alexander Rd & Van Lanningham Rd

CATS Route ID: 29

CATS Route Name: UNCC / JW Clay

Total Cost: \$ 1450.00

