


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 12377	Main Street: S_TRYON_ST	Cross Street: E_4TH_ST	Location: E
ADA ID: EAB6507BC201	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5, R302.6

CATS Stop ID: **25650**

CATS Stop Description: **4th St & Tryon St**

CATS Route ID: **34, 40x, 41x, 46x, 48x, 52x, 61x, 62x, 64x, 65x, 7, 74x**

CATS Route Name: **Multiple**

Total Cost: \$ **3400.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	137.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.7
Yes	Boarding Area XSlope %	0.7
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	52.0
Yes	PAR 1 Slope %	0.3
No	PAR 1 XSlope %	3.4
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	52.0
No	PAR 2 Slope %	4.6
No	PAR 2 XSlope %	4.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.7
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	No
No	Protruding Objects?	Yes

