


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 4175	Main Street: LAKEVIEW_RD	Cross Street: STATESVILLE_RD	Location: W
ADA ID: EBEFC6641BE3	Overall Compliance: No	Severity Score: 60	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Provide Clear Floor Space. Remove
or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.4, 810.3, R302,
R308.1.1.2, R404.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	150.0
Yes	Boarding Area Length (in)	118.0
No	Boarding Area Slope %	4.0
No	Boarding Area XSlope %	2.5
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	1.4
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	84.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 46381

CATS Stop Description: Statesville Rd & Lakeview Rd

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 3700.00

