


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10037824	Main Street: SHARON_RD_WEST	Cross Street: N/A	Location: S
ADA ID: ECF3744FED69	Overall Compliance: No	Severity Score: 30	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 305.3, 402.2, 810.2.3, 810.3, R302, R302.6, R404.1, R404.2, R404.3

CATS Stop ID: **28370**

CATS Stop Description: **Sharon Rd West & Sharon Lakes Rd**

CATS Route ID: **12, 43**

CATS Route Name: **Multiple**

Total Cost: \$ **3200.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	104.0
Yes	Boarding Area Slope %	1.3
Yes	Boarding Area XSlope %	6.7
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	6.7
Yes	PAR 1 XSlope %	1.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	6.4
No	PAR 2 XSlope %	2.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	6.9
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	92.0
No	Clear Floor Space Length (in)	39.0
Yes	Clear Floor Space Slope %	1.2
No	Clear Floor Space XSlope %	6.3
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

