


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                                |                                         |              |
|-----------------------------------------|--------------------------------|-----------------------------------------|--------------|
| Intersection ID: 10023165               | Main Street: CHARLOTTETOWNE_AV | Cross Street: N/A                       | Location: NE |
| ADA ID: EF1C6EF3AFDD                    | Overall Compliance: No         | Severity Score: 40                      |              |
| Codes/Mitigation Info/Possible Solution |                                | Field Measurements/Component Compliance |              |



## Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Provide Clear Floor  
Space. Remove or Relocate  
Protruding Objects/Obstructions.**

## Surveyor Notes:

**N/A**

## PROW/ADA:

**402.2, 810.2.3, 810.2.4, 810.3, R302,  
R302.5, R302.6, R308.1.1.2, R404.1**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 60.0  |
| Yes        | Boarding Area Length (in)       | 103.0 |
| No         | Boarding Area Slope %           | 2.5   |
| Yes        | Boarding Area XSlope %          | 1.6   |
| No         | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 97.0  |
| Yes        | PAR 1 Slope %                   | 0.6   |
| No         | PAR 1 XSlope %                  | 3.1   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| No         | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 97.0  |
| Yes        | PAR 2 Slope %                   | 1.5   |
| No         | PAR 2 XSlope %                  | 2.8   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 1.3   |
| N/A        | Shelter                         | Yes   |
| No         | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 97.0  |
| N/A        | Bench?                          | Yes   |
| No         | Protruding Objects?             | Yes   |

CATS Stop ID: **46143**

CATS Stop Description: **Charlottetowne Ave & Kings Dr**

CATS Route ID: **6**

CATS Route Name: **Kings Drive**

Total Cost: \$ **4600.00**

