


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10016076	Main Street: TIPPERARY_PL	Cross Street: N/A	Location: W
ADA ID: EFE894EC75BD	Overall Compliance: No	Severity Score: 15	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 403.5.1, 810.2.3, R302, R302.3, R302.5

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	0.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	47.0
No	PAR 2 Slope %	3.2
Yes	PAR 2 XSlope %	1.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.2
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	73.5
Yes	Clear Floor Space Length (in)	48.0
Yes	Clear Floor Space Slope %	1.0
Yes	Clear Floor Space XSlope %	0.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 32190

CATS Stop Description: Tipperary PI & Foxford PI

CATS Route ID: 23

CATS Route Name: Shamrock Drive

Total Cost: \$ 3400.00

