


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10014038	Main Street: E_36TH_ST	Cross Street: THE_PLAZA	Location: N
ADA ID: F104D79EBCDB	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2.2, R308.1.1.1

CATS Stop ID: 33560

CATS Stop Description: 36th St & The Plaza

CATS Route ID: 23, 3

CATS Route Name: Multiple

Total Cost: \$ 750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	82.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	0.2
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	65.0
Yes	PAR 1 Slope %	0.2
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	87.0
Yes	PAR 2 Slope %	0.4
Yes	PAR 2 XSlope %	0.9
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.7
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	40.0
Yes	Clear Floor Space Length (in)	61.0
Yes	Clear Floor Space Slope %	1.0
Yes	Clear Floor Space XSlope %	1.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

