


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 6998	Main Street: NEVIN_RD	Cross Street: STATESVILLE_RD	Location: NW
ADA ID: F1B17357B2B2	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, 810.3, R302, R302.6, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	120.0
Yes	Boarding Area Length (in)	120.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	2.0
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
No	PAR 1 Slope %	2.6
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.2
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 30615

CATS Stop Description: Statesville Rd & Nevin Rd

CATS Route ID: 21

CATS Route Name: Statesville Ave

Total Cost: \$ 1150.00

