


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033921	Main Street: PARK_RD	Cross Street: N/A	Location: W
ADA ID: F6845CACAE30	Overall Compliance: No	Severity Score: 30	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

GRADE BREAK IN BOARDING AREA

PROW/ADA:

810.2.4, R308.1.1.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	63.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	6.0
Yes	Boarding Area XSlope %	2.0
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
Yes	PAR 1 Slope %	0.5
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	2.0
Yes	PAR 2 XSlope %	2.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	48.0
N/A	Clear Floor Space Length (in)	48.0
N/A	Clear Floor Space Slope %	6.0
N/A	Clear Floor Space XSlope %	2.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 20520

CATS Stop Description: Park Rd & Ideal Way

CATS Route ID: 19

CATS Route Name: Park Road

Total Cost: \$ 750.00

