


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041752	Main Street: WILKINSON_BV	Cross Street: N/A	Location: N
ADA ID: F77C286B2487	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 403.5.1, 810.2.3,
810.2.4, 810.3, R302, R302.3, R302.5,
R302.6, R308.1.1.2, R404.1, R404.2**

CATS Stop ID: **35180**

CATS Stop Description: **Wilkinson Blvd & Ashley Rd**

CATS Route ID: **235, 5**

CATS Route Name: **Multiple**

Total Cost: \$ **3950.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	154.0
No	Boarding Area Slope %	2.1
Yes	Boarding Area XSlope %	1.9
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.0
No	PAR 1 Slope %	3.2
No	PAR 1 XSlope %	3.5
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.7
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	60.0
Yes	Clear Floor Space Length (in)	60.0
No	Clear Floor Space Slope %	2.7
No	Clear Floor Space XSlope %	2.5
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

