


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10036892	Main Street: S_MCDOWELL_ST	Cross Street: N/A	Location: SE
ADA ID: FACD4646F352	Overall Compliance: No	Severity Score: 45	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.2, 810.2.3, R302, R302.6,
R308.1.1.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	72.0
No	Boarding Area Length (in)	84.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	1.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	77.0
Yes	PAR 1 Slope %	0.8
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	77.0
Yes	PAR 2 Slope %	0.7
No	PAR 2 XSlope %	2.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.7
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 25580

CATS Stop Description: **McDowell St & Baxter St**

CATS Route ID: 20

CATS Route Name: **Queens Road**

Total Cost: \$ 1450.00

