


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 5264	Main Street: BEATTIES_FORD_RD	Cross Street: MCINTYRE_AV	Location: NW
ADA ID: FE80EC2E91CE	Overall Compliance: N/A	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

CATS Stop ID: 42645

CATS Stop Description: Beatties Ford Rd & McIntyre Ave

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	120.0
Yes	Boarding Area Length (in)	120.0
Yes	Boarding Area Slope %	0.7
Yes	Boarding Area XSlope %	0.4
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.1
Yes	PAR 1 XSlope %	2.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	87.0
N/A	Bench?	No
Yes	Protruding Objects?	No

