

Access Compliance Report

Public Rights-of-Way

(Accessible Street Parking)

Intersection ID: N/A	Main Street: CLANTON RD	Location: N/A
ADA ID: 07C65C0A3AE2	ParkingType: ParaPark	Overall Compliance: No
		Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:


Advise relocating to an area with maximum 2% slopes

Surveyor Notes:

N/A

PROW/ADA:

TBD



Total Cost: \$ \$0.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Parking Spot At End of Block?	No	Yes	Accessible Route?	Yes
Yes	Adjacent Sidewalk Width (in)	96.0	No	Access Aisle Marking?	Yes
No	Adjacent Sidewalk Slope (%)	2.6	No	Access Aisle Width (in)	57.0
Yes	Adjacent Sidewalk XSlope (%)	2.0	No	Access Aisle Length (in)	233.0
Yes	Adjacent Sidewalk Clear of Obstr.	Yes	N/A	Access Aisle Location	Side
	N/A	Parking Spot Width (in)		91.0	
	N/A	Parking Spot Length (in)		261.0	
	N/A	Van Accessible?		N/A	
	Yes	Curb Ramp?		Yes	
	N/A	Identification Sign?		N/A	
	N/A	Sign Height (in)		N/A	
	N/A	Vertical Clearance		N/A	
	N/A	Parking Meter?		N/A	
	N/A	Parking Meter Height (in)		N/A	
	N/A	Meter Operable Parts?		N/A	
	N/A	Meter Clear Space?		N/A	
	N/A	Meter Clear Space Slope (%)		N/A	
	N/A	Meter Clear Space XSlope (%)		N/A	
	N/A	Meter Forward Reach?		N/A	
	N/A	Meter Forward Reach (in)		N/A	
	N/A	Meter Parallel Reach?		N/A	
	N/A	Meter Parallel Reach (in)		N/A	

N/A	Parking Space/Access Aisle Slopes (%)							
	C Slope (%)	1.3	D Slope (%)	2.6	I Slope (%)	N/A	L Slope (%)	N/A
	B Slope (%)	2.4	E Slope (%)	1.4	H Slope (%)	N/A	K Slope (%)	N/A
	A Slope (%)	2.9	F Slope (%)	2.4	G Slope (%)	N/A	J Slope (%)	N/A
N/A	Parking Space/Access Aisle XSlopes (%)							
	C XSlope (%)	0.1	D XSlope (%)	1.1	I XSlope (%)	N/A	L XSlope (%)	N/A
	B XSlope (%)	1.2	E XSlope (%)	2.7	H XSlope (%)	N/A	K XSlope (%)	N/A
	A XSlope (%)	0.8	F XSlope (%)	1.0	G XSlope (%)	N/A	J XSlope (%)	N/A

