

Access Compliance Report

Public Rights-of-Way

(Accessible Street Parking)

| | | |
|---|--------------------------|---|
| Intersection ID: N/A | Main Street: W SUMMIT AV | Location: N/A |
| ADA ID: 1EC8411CC6C5 | ParkingType: ParaPark | Overall Compliance: No |
| | | Severity Score: 0.0 |
| Codes/Mitigation Info/Possible Solution | | Field Measurements/Component Compliance |



Possible Solutions:

Advise relocating to an area with maximum 2% slopes


Surveyor Notes:

N/A

PROW/ADA:

TBD

| Compliance | Description | Data | Compliance | Description | Data |
|------------|-----------------------------------|------------------------------|------------|--------------------------|-------|
| N/A | Parking Spot At End of Block? | Yes | Yes | Accessible Route? | Yes |
| Yes | Adjacent Sidewalk Width (in) | 96.0 | No | Access Aisle Marking? | No |
| Yes | Adjacent Sidewalk Slope (%) | 2.0 | N/A | Access Aisle Width (in) | 60.0 |
| Yes | Adjacent Sidewalk XSlope (%) | 0.9 | N/A | Access Aisle Length (in) | 260.0 |
| Yes | Adjacent Sidewalk Clear of Obstr. | Yes | N/A | Access Aisle Location | N/A |
| | N/A | Parking Spot Width (in) | | 82.0 | |
| | N/A | Parking Spot Length (in) | | 260.0 | |
| | N/A | Van Accessible? | | N/A | |
| | No | Curb Ramp? | | No | |
| | N/A | Identification Sign? | | N/A | |
| | N/A | Sign Height (in) | | N/A | |
| | N/A | Vertical Clearance | | N/A | |
| | N/A | Parking Meter? | | N/A | |
| | N/A | Parking Meter Height (in) | | N/A | |
| | N/A | Meter Operable Parts? | | N/A | |
| | N/A | Meter Clear Space? | | N/A | |
| | N/A | Meter Clear Space Slope (%) | | N/A | |
| | N/A | Meter Clear Space XSlope (%) | | N/A | |
| | N/A | Meter Forward Reach? | | N/A | |
| | N/A | Meter Forward Reach (in) | | N/A | |
| | N/A | Meter Parallel Reach? | | N/A | |
| | N/A | Meter Parallel Reach (in) | | N/A | |



Total Cost: \$ \$0.00

| | | | | | | |
|--------------|--|--------------|-----|--------------|-----|--------------|
| N/A | Parking Space/Access Aisle Slopes (%) | | | | | |
| C Slope (%) | 2.9 | D Slope (%) | 4.1 | I Slope (%) | N/A | L Slope (%) |
| B Slope (%) | 4.4 | E Slope (%) | 3.6 | H Slope (%) | N/A | K Slope (%) |
| A Slope (%) | 3.4 | F Slope (%) | 1.9 | G Slope (%) | N/A | J Slope (%) |
| N/A | Parking Space/Access Aisle XSlopes (%) | | | | | |
| C XSlope (%) | 1.5 | D XSlope (%) | 0.8 | I XSlope (%) | N/A | L XSlope (%) |
| B XSlope (%) | 3.9 | E XSlope (%) | 1.7 | H XSlope (%) | N/A | K XSlope (%) |
| A XSlope (%) | 5.1 | F XSlope (%) | 3.8 | G XSlope (%) | N/A | J XSlope (%) |

