


# Access Compliance Report

## Public Rights-of-Way

### (Accessible Street Parking)

Intersection ID: N/A	Main Street: S BREVARD ST	Location: N/A
ADA ID: 278DC137147C	ParkingType: ParaPark	Overall Compliance: No
		Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:


**Advise relocating to an area with maximum 2% slopes**

Surveyor Notes:

**N/A**

PROW/ADA:

**TBD**



Total Cost: \$ **\$0.00**

Compliance	Description	Data	Compliance	Description	Data
N/A	Parking Spot At End of Block?	Yes	Yes	Accessible Route?	Yes
Yes	Adjacent Sidewalk Width (in)	95.0	No	Access Aisle Marking?	Yes
Yes	Adjacent Sidewalk Slope (%)	0.5	No	Access Aisle Width (in)	52.0
No	Adjacent Sidewalk XSlope (%)	2.3	No	Access Aisle Length (in)	148.0
N/A	Adjacent Sidewalk Clear of Obstr.	N/A	N/A	Access Aisle Location	Front
	N/A	Parking Spot Width (in)		70.0	
	N/A	Parking Spot Length (in)		238.0	
	N/A	Van Accessible?		N/A	
	Yes	Curb Ramp?		Yes	
	N/A	Identification Sign?		N/A	
	N/A	Sign Height (in)		N/A	
	N/A	Vertical Clearance		N/A	
	N/A	Parking Meter?		N/A	
	N/A	Parking Meter Height (in)		N/A	
	N/A	Meter Operable Parts?		N/A	
	N/A	Meter Clear Space?		N/A	
	N/A	Meter Clear Space Slope (%)		N/A	
	N/A	Meter Clear Space XSlope (%)		N/A	
	N/A	Meter Forward Reach?		N/A	
	N/A	Meter Forward Reach (in)		N/A	
	N/A	Meter Parallel Reach?		N/A	
	N/A	Meter Parallel Reach (in)		N/A	

<b>N/A</b>	Parking Space/Access Aisle Slopes (%)							
	C Slope (%)	<b>2.0</b>	D Slope (%)	<b>0.3</b>	I Slope (%)	<b>N/A</b>	L Slope (%)	<b>N/A</b>
	B Slope (%)	<b>1.3</b>	E Slope (%)	<b>0.2</b>	H Slope (%)	<b>N/A</b>	K Slope (%)	<b>N/A</b>
	A Slope (%)	<b>0.7</b>	F Slope (%)	<b>0.5</b>	G Slope (%)	<b>N/A</b>	J Slope (%)	<b>N/A</b>
<b>N/A</b>	Parking Space/Access Aisle XSlopes (%)							
	C XSlope (%)	<b>3.1</b>	D XSlope (%)	<b>1.7</b>	I XSlope (%)	<b>N/A</b>	L XSlope (%)	<b>N/A</b>
	B XSlope (%)	<b>2.9</b>	E XSlope (%)	<b>4.8</b>	H XSlope (%)	<b>N/A</b>	K XSlope (%)	<b>N/A</b>
	A XSlope (%)	<b>5.2</b>	F XSlope (%)	<b>5.8</b>	G XSlope (%)	<b>N/A</b>	J XSlope (%)	<b>N/A</b>

