


# Access Compliance Report

## Public Rights-of-Way

### (Accessible Street Parking)

Intersection ID: 10035679	Main Street: RED_RUST_LN	Location:	N/A
ADA ID: 27B98AEF31AD	ParkingType: ParaPark	Overall Compliance: No	Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:


**Advise relocating to an area with maximum 2% slopes**

Surveyor Notes:

**N/A**

PROW/ADA:

**TBD**



Total Cost: \$ **\$0.00**

Compliance	Description	Data	Compliance	Description	Data
N/A	Parking Spot At End of Block?	Yes	Yes	Accessible Route?	Yes
Yes	Adjacent Sidewalk Width (in)	131.0	No	Access Aisle Marking?	No
Yes	Adjacent Sidewalk Slope (%)	2.2	N/A	Access Aisle Width (in)	60.0
Yes	Adjacent Sidewalk XSlope (%)	0.2	N/A	Access Aisle Length (in)	281.0
Yes	Adjacent Sidewalk Clear of Obstr.	Yes	N/A	Access Aisle Location	Side
	N/A	Parking Spot Width (in)		81.0	
	N/A	Parking Spot Length (in)		399.5	
	N/A	Van Accessible?		N/A	
	Yes	Curb Ramp?		Yes	
	N/A	Identification Sign?		N/A	
	N/A	Sign Height (in)		N/A	
	N/A	Vertical Clearance		N/A	
	N/A	Parking Meter?		N/A	
	N/A	Parking Meter Height (in)		N/A	
	N/A	Meter Operable Parts?		N/A	
	N/A	Meter Clear Space?		N/A	
	N/A	Meter Clear Space Slope (%)		N/A	
	N/A	Meter Clear Space XSlope (%)		N/A	
	N/A	Meter Forward Reach?		N/A	
	N/A	Meter Forward Reach (in)		N/A	
	N/A	Meter Parallel Reach?		N/A	
	N/A	Meter Parallel Reach (in)		N/A	

<b>N/A</b>	Parking Space/Access Aisle Slopes (%)							
C Slope (%)	<b>2.2</b>	D Slope (%)	<b>1.8</b>	I Slope (%)	<b>N/A</b>	L Slope (%)	<b>N/A</b>	
B Slope (%)	<b>2.0</b>	E Slope (%)	<b>3.1</b>	H Slope (%)	<b>N/A</b>	K Slope (%)	<b>N/A</b>	
A Slope (%)	<b>0.6</b>	F Slope (%)	<b>3.0</b>	G Slope (%)	<b>N/A</b>	J Slope (%)	<b>N/A</b>	
<b>N/A</b>	Parking Space/Access Aisle XSlopes (%)							
C XSlope (%)	<b>3.5</b>	D XSlope (%)	<b>2.0</b>	I XSlope (%)	<b>N/A</b>	L XSlope (%)	<b>N/A</b>	
B XSlope (%)	<b>3.6</b>	E XSlope (%)	<b>1.7</b>	H XSlope (%)	<b>N/A</b>	K XSlope (%)	<b>N/A</b>	
A XSlope (%)	<b>5.9</b>	F XSlope (%)	<b>4.7</b>	G XSlope (%)	<b>N/A</b>	J XSlope (%)	<b>N/A</b>	

