


Access Compliance Report

Public Rights-of-Way

(Accessible Street Parking)

Intersection ID: 10033477	Main Street: OLD_PINEVILLE_RD	Location: N/A
ADA ID: A748C96C4496	ParkingType: ParaPark	Overall Compliance: No
		Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:

Advise relocating to an area with maximum 2% slopes

Surveyor Notes:


N/A

PROW/ADA:

TBD

Compliance	Description	Data	Compliance	Description	Data
N/A	Parking Spot At End of Block?	No	Yes	Accessible Route?	Yes
Yes	Adjacent Sidewalk Width (in)	48.0	N/A	Access Aisle Marking?	Yes
Yes	Adjacent Sidewalk Slope (%)	1.6	Yes	Access Aisle Width (in)	91.0
Yes	Adjacent Sidewalk XSlope (%)	0.8	Yes	Access Aisle Length (in)	256.0
N/A	Adjacent Sidewalk Clear of Obstr.	N/A	N/A	Access Aisle Location	Side
	N/A	Parking Spot Width (in)		104.0	
	N/A	Parking Spot Length (in)		256.0	
	N/A	Van Accessible?		N/A	
	No	Curb Ramp?		No	
	N/A	Identification Sign?		N/A	
	N/A	Sign Height (in)		N/A	
	N/A	Vertical Clearance		N/A	
	N/A	Parking Meter?		N/A	
	N/A	Parking Meter Height (in)		N/A	
	N/A	Meter Operable Parts?		N/A	
	N/A	Meter Clear Space?		N/A	
	N/A	Meter Clear Space Slope (%)		N/A	
	N/A	Meter Clear Space XSlope (%)		N/A	
	N/A	Meter Forward Reach?		N/A	
	N/A	Meter Forward Reach (in)		N/A	
	N/A	Meter Parallel Reach?		N/A	
	N/A	Meter Parallel Reach (in)		N/A	

Total Cost: \$ \$0.00



N/A	Parking Space/Access Aisle Slopes (%)						
	C Slope (%)	2.0	D Slope (%)	1.8	I Slope (%)	N/A	L Slope (%)
	B Slope (%)	1.8	E Slope (%)	2.0	H Slope (%)	N/A	K Slope (%)
	A Slope (%)	2.3	F Slope (%)	2.6	G Slope (%)	N/A	J Slope (%)
N/A	Parking Space/Access Aisle XSlopes (%)						
	C XSlope (%)	1.2	D XSlope (%)	0.7	I XSlope (%)	N/A	L XSlope (%)
	B XSlope (%)	2.1	E XSlope (%)	0.7	H XSlope (%)	N/A	K XSlope (%)
	A XSlope (%)	2.4	F XSlope (%)	0.1	G XSlope (%)	N/A	J XSlope (%)

