


Access Compliance Report

Public Rights-of-Way

(Accessible Street Parking)

Intersection ID: 10040668	Main Street: W_MARTIN_LUTHER_KING_JR_BV	Location: N/A
ADA ID: F2606FEB807C	ParkingType: ParaPark	Overall Compliance: No
		Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:

Advise relocating to an area with maximum 2% slopes


Surveyor Notes:

N/A

PROW/ADA:

TBD

Compliance	Description	Data	Compliance	Description	Data
N/A	Parking Spot At End of Block?	Yes	Yes	Accessible Route?	Yes
Yes	Adjacent Sidewalk Width (in)	184.0	No	Access Aisle Marking?	No
Yes	Adjacent Sidewalk Slope (%)	3.5	N/A	Access Aisle Width (in)	61.0
No	Adjacent Sidewalk XSlope (%)	3.9	N/A	Access Aisle Length (in)	249.0
Yes	Adjacent Sidewalk Clear of Obstr.	Yes	N/A	Access Aisle Location	Side
	N/A	Parking Spot Width (in)		91.0	
	N/A	Parking Spot Length (in)		292.0	
	N/A	Van Accessible?		N/A	
	Yes	Curb Ramp?		Yes	
	N/A	Identification Sign?		N/A	
	N/A	Sign Height (in)		N/A	
	N/A	Vertical Clearance		N/A	
	N/A	Parking Meter?		N/A	
	N/A	Parking Meter Height (in)		N/A	
	N/A	Meter Operable Parts?		N/A	
	N/A	Meter Clear Space?		N/A	
	N/A	Meter Clear Space Slope (%)		N/A	
	N/A	Meter Clear Space XSlope (%)		N/A	
	N/A	Meter Forward Reach?		N/A	
	N/A	Meter Forward Reach (in)		N/A	
	N/A	Meter Parallel Reach?		N/A	
	N/A	Meter Parallel Reach (in)		N/A	



Total Cost: \$ \$0.00

N/A	Parking Space/Access Aisle Slopes (%)						
	C Slope (%)	3.5	D Slope (%)	3.3	I Slope (%)	N/A	L Slope (%)
	B Slope (%)	4.6	E Slope (%)	3.6	H Slope (%)	N/A	K Slope (%)
	A Slope (%)	3.8	F Slope (%)	3.8	G Slope (%)	N/A	J Slope (%)
N/A	Parking Space/Access Aisle XSlopes (%)						
	C XSlope (%)	3.8	D XSlope (%)	8.6	I XSlope (%)	N/A	L XSlope (%)
	B XSlope (%)	4.6	E XSlope (%)	8.1	H XSlope (%)	N/A	K XSlope (%)
	A XSlope (%)	3.5	F XSlope (%)	7.8	G XSlope (%)	N/A	J XSlope (%)

