

Access Compliance Report Public Rights-of-Way (RR Crossings)

Intersection ID: 10035376	Main Street: RAMA_RD	Location: N/A
ADA ID: 285B18933CC8	Overall Compliance: No	Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:

**Install Detectable Warning System.
Remove & Replace Walking Surface
Adjacent to Rail.**

Surveyor Notes:

N/A

PROW/ADA:

R208.1, R302.7.4

Compliance	Description	Data
No	DWS Provided?	No
N/A	DWS Contrast?	No
N/A	DWS Width (in)	No
N/A	DWS Length (in)	N/A
N/A	DWS Offset (in)	N/A
Yes	Pedestrian Gate?	Yes
N/A	DWS Outside Gate?	No
N/A	Rail Type?	Freight
No	Flangeway Gap (in)	3.0
Yes	Sidewalk Width (in)	60.0

Total Cost: \$ 635.00

