


Access Compliance Report Public Rights-of-Way (RR Crossings)

Intersection ID: 15833	Main Street: SOUTH_BV	Location: N/A
ADA ID: A7EE25CE0D87	Overall Compliance: No	Severity Score: 0.0
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Detectable
Warning System. Provide Pedestrian
Gate.**

Surveyor Notes:

N/A

PROW/ADA:

R305.1.4, R305.2.5

Compliance	Description	Data
Yes	DWS Provided?	Yes
Yes	DWS Contrast?	Yes
No	DWS Width (in)	No
Yes	DWS Length (in)	24.0
No	DWS Offset (in)	61.0
No	Pedestrian Gate?	No
N/A	DWS Outside Gate?	No
N/A	Rail Type?	N/A
N/A	Flangeway Gap (in)	2.5
Yes	Sidewalk Width (in)	78.0

Total Cost: \$ 2800.00

